

EG4[®] MONITOR CENTER

OVERVIEW

The EG4 Monitor Center has new features that allow the end-user to easily check real-time system information regarding inverters, batteries, and other informative values. The images and descriptions in this guide will provide an overview of the EG4 Monitor Center, its settings and what they entail.




TABLE OF CONTENTS

1.	MONITOR CENTER OVERVIEW.....	1
2.	MONITOR TAB.....	4
2.1	SOLAR YIELD	4
2.2	BATTERY DISCHARGE/CHARGE	5
2.3	FEED-IN ENERGY/IMPORT	5
2.4	CONSUMPTION.....	5
2.5	SYSTEM INFORMATION	6
2.6	EXTENDED SYSTEM INFORMATION.....	7
2.7	BATTERY INFORMATION.....	8
2.8	INPUT & OUTPUT POWER	9
2.9	ENERGY OVERVIEW	9
3.	DATA TAB	10
3.1	CHART	10
3.2	ENERGY.....	12
3.3	DATA HISTORY	13
3.4	LOCAL DATA	13
3.5	EVENT HISTORY.....	14
4.	CONFIGURATION TAB.....	14
4.1	STATIONS.....	14
4.2	DONGLES.....	15
4.3	DEVICES	15
4.4	USERS.....	15
5.	OVERVIEW TAB.....	16
5.1	STATION OVERVIEW.....	16
5.2	DEVICE OVERVIEW.....	16
6.	MAINTENANCE TAB.....	17
6.1	REMOTE SET	17
6.2	WEATHER OPTIMIZE	26
6.3	REMOTE UPDATE.....	28

1. MONITOR CENTER OVERVIEW


The EG4® Monitor Center is a cloud-based software that is accessible using a web browser. Begin by navigating to the EG4 Monitor Center website (*shown below*) and signing in.






NOTE:

Certain features shown in this guide are only available on select EG4® inverter models.



Once signed in to the Monitor Center, the user is placed on the default landing page. This page is referred to as the “Monitor” tab. Located at the top of the Monitor Center page, there are 5 tabs that can be selected.


- A. Monitor** – The “Monitor” tab displays Solar Yield, Battery Discharge/Charge, Feed-In Energy/Import, Consumption, and real time System Information.
- B. Data** – The “Data” tab contains detailed charts and data for inverters, solar arrays (if applicable) and batteries. This tab also has 5 pages.
 - **Chart** – Displays various parameters in chart format over a 24-hour period. There are separate charts for “PV Side,” “Battery,” “AC Side,” “Backup Output,” “Gen Side,” and “Internal Sample.”
 - **Energy** – Displays how key energy parameters have varied over time.
 - **Data History** – Displays the measured technical values of PV, battery, load, and grid for users or their distributor’s examination to promptly address any potential issues.
 - **Local Data** – The data captured during the offline periods are displayed in the "Local data" section (loss of internet or Wi-Fi).
 - **Event History** – The "Event History" section displays a timeline of Notice and Fault events.



NOTE:


The “Data” tab will only display information on solar arrays when using Tlgo Optimizers.

- C. Configuration** – The “Configuration” tab is designated for users to manage their station, dongle, and user information. This tab has 4 pages.
 - **Stations** – The “Stations” section will show all stations linked to the account. Selecting a station name will display all inverters under that station or location.
 - **Dongles** – Users can add the dongle Serial Number (SN) in the station if they have more than one inverter in the station.
 - **Devices** – Users can view the general data for each of the inverters tied to the user’s account.
 - **Users** – This page shows a full list of users, distributors, and any other roles linked to the account.




D. Overview – The "Overview" tab allows EG4® or its distributors to quickly monitor system-wide data for their end users, such as solar yields, battery discharging, and other factors. This tab will have 2 pages.

- **Station Overview** – All stations linked to the account can be found here.
- **Device Overview** – All inverters linked to the account can be found here.



E. Maintenance – The "Maintenance" tab allows the end-user to set up and update their system. This tab will have 3 pages.

- **Remote Set** – This page will allow end users to set up their system for their specifications and uses.
- **Weather Optimize** – This page will allow the end user to set up their system for the best results according to weather conditions.
- **Remote Update** – This page shows all firmware updates for the system, past or present.



To access more on the "Data", "Configuration", "Overview", and "Maintenance" tabs, navigate to the corresponding sections in this document. This provides the end user more information of what each tab does and the information within each subpage.


2. MONITOR TAB

After logging in to the EG4® Monitor Center and setting up the station, confirm that the correct inverter station has been selected. The default selection upon logging in will take the end-user to the “Monitor” tab, showing real time System Information, with tabs across the top of the screen. See *image below*.



NOTE:


Settings will vary depending on which inverter and firmware version is installed.



2.1 SOLAR YIELD

The data in this section shows power generated by the solar array. AC coupled inverters will display the power generated by the grid-tied inverter. To accurately show data, the PV CT clamp for the AC ESS inverter will have to be installed. When the “Solar Yield” image is selected, the area displays the amount of solar energy used that day and a second mouse click displays the total Solar Yield since commissioning the system (see *images below*). Solar Yield data also includes the percentage portion of load supplied, total charge of battery, and total energy exported.

Daily usage



Total since commissioning



2.2 BATTERY DISCHARGE/CHARGE

The data in this section shows the charge and discharge of energy from the battery bank. When the battery picture is selected, the display will switch between Battery Discharge and Battery Charge showing totals for that day and since commissioning.




2.3 FEED-IN ENERGY/IMPORT

Displays energy exported to grid for that day and since commissioning. When the image is selected, it shows energy imported from the grid for that day and since commissioning.




2.4 CONSUMPTION

The data in this section displays the total energy consumption of the location for that day and since commissioning.



2.5 SYSTEM INFORMATION

The image below displays live energy data with dynamic flows.



A. Battery Information – When the battery image is selected, the display will show battery charge and discharge limitations. The battery image color represents the following: Green = Healthy, Yellow = Warning, Red = Fault.

B. Solar Yield – The data will show the watts and volts that each array in the system is producing.

C. Status – The end-user can see what state their inverter is in.

- **Grey color:** Inverter is offline and will stop power input and output.
- **Green color:** Inverter is functioning properly.
- **Orange color:** Inverter has experienced an event with a level of Notice or Warning. *See note below.*
- **Red color:** Inverter has a fault.



NOTE:

Selecting the “Notice” event type will display the event(s) within the Data Tab under Event History (see image below).

Station	Serial number	Event Type	Event	Start Time	Time Recovered
1 (Station Name)	3383740027	Notice	W015: No AC Connection	2024-06-03 20:49:14	2024-06-05 21:50:18
2 (Station Name)	3383740027	Notice	W015: No AC Connection	2024-05-31 21:10:55	2024-05-31 21:27:10
3 (Station Name)	3383740027	Notice	W015: No AC Connection	2024-05-28 09:06:36	2024-05-31 20:49:14
4 (Station Name)	3383740027	Notice	W025: Battery voltage high	2024-05-17 14:23:07	2024-05-17 14:24:07
5 (Station Name)	3383740027	Notice	W028: EPS Over load	2024-05-16 21:10:57	2024-05-16 21:12:59
6 (Station Name)	3383740027	Notice	W028: EPS Over load	2024-05-16 21:02:54	2024-05-16 21:03:53
7 (Station Name)	3383740027	Notice	W028: EPS Over load	2024-05-16 20:57:53	2024-05-16 20:59:52
8 (Station Name)	3383740027	Notice	W028: EPS Over load	2024-05-16 20:55:50	2024-05-16 20:56:51



NOTE:

Selecting the “Fault” event type will display the event(s) within the Data Tab under Event History (see image below).


Station	Serial number	Event Type	Event	Start Time	Time Recovered
1		Fault	E000: Internal communication fault 1	2024-04-26 13:21:27	
2		Notice	W016: No AC Connection	2024-04-26 13:19:26	2024-04-26 13:20:26
3		Fault	E000: Internal communication fault 1	2024-04-26 13:15:19	2024-04-26 13:19:26
4		Notice	W016: No AC Connection	2024-04-26 13:13:19	2024-04-26 13:14:18
5		Fault	E000: Internal communication fault 1	2024-04-26 12:40:22	2024-04-26 13:13:19
6		Notice	W016: No AC Connection	2024-04-26 12:38:42	2024-04-26 12:39:42
7		Fault	E000: Internal communication fault 1	2024-04-26 12:33:18	2024-04-26 12:38:42

EPS – The system converts power from battery/solar to AC line 1 and 2. EPS L1N and L2N will display the amount of watts consumed on each line.

- D. Utility/Grid** – Displays the grid input is present.
- E. Consumption Power** – When the inverter is running in bypass mode, this value shows the power being pulled from the grid.
- F. Start Functions** – Three start options for Gen Exercise, Quick Charge and Battery Backup.
 - **Start Gen Exercise** – Starts generator automatically to ensure it is functioning properly.
 - **Start Quick Charge** – Takes AC power for one hour and diverts it to charge batteries while putting the inverter in Bypass Mode.
 - **Start Battery Backup** – The battery will charge all the way and not discharge until the grid goes down or selected to stop.

2.6 EXTENDED SYSTEM INFORMATION

The image below shows additional battery information. See callout 6 on Page 4 for full screen.



- **Remain Cap:** Remaining Ah capacity in the battery.
- **Full Cap:** Remaining Ah capacity in the full bank.
- **Total Battery:** The number of batteries.
- **Discharge Current:** Total discharge for all batteries.
- **Total Voltage:** Total voltage for entire bank.

2.7 BATTERY INFORMATION

Next, scroll down the “Monitor” tab and this section will show the number of batteries an end-user has on their system. Here the end-user will be able to see additional values of the battery bank.

Battery Information <input type="checkbox"/> Show all parameters							
Battery 0 - EG4_485-1_ID02 - V 0.00		Battery 1 - EG4_485-1_ID03 - V 0.00		Battery 2 - EG4_485-1_ID05 - V 0.00		Battery 3 - EG4_485-1_ID06 - V 3.37	
52.28 V Total Vol	78 % SOC	52.29 V Total Vol	80 % SOC	52.3 V Total Vol	82 % SOC	52.33 V Total Vol	79 % SOC
-48.9 A Current	100 % SOH	-43.9 A Current	100 % SOH	-39.2 A Current	0 % SOH	-44.7 A Current	98 % SOH

- **Battery ID** – The name of the battery.
- **Total Voltage** – Total voltage of the battery.
- **SOC** – The state of charge of the battery.
- **Current** – The charge/discharge current of the battery.
- **SOH** – State of health of the battery.

Show all parameters: Select the check box to display additional details about the battery.


Battery Information <input type="checkbox"/> Show all parameters	Battery Information <input checked="" type="checkbox"/> Show all parameters
--	---

Battery Information <input checked="" type="checkbox"/> Show all parameters							
Battery 0 - EG4_485-1_ID02 - V 0.00		Battery 1 - EG4_485-1_ID03 - V 0.00		Battery 2 - EG4_485-1_ID04 - V 0.00		Battery 3 - EG4_485-1_ID05 - V 0.00	
51.45 V Total Vol	33 % SOC	51.47 V Total Vol	38 % SOC	51.47 V Total Vol	46 % SOC	51.5 V Total Vol	43 % SOC
-43.5 A Current	100 % SOH	-42.1 A Current	100 % SOH	-37.8 A Current	0 % SOH	-40 A Current	0 % SOH
29 °C Min Temp / Cell 0	29 °C Max Temp / Cell 0	28 °C Min Temp / Cell 0	29 °C Max Temp / Cell 0	25 °C Min Temp / Cell 0	25 °C Max Temp / Cell 0	26 °C Min Temp / Cell 0	26 °C Max Temp / Cell 0
3.213 V Min Volt / Cell 3	3.218 V Max Volt / Cell 4	3.215 V Min Volt / Cell 6	3.219 V Max Volt / Cell 10	3.18 V Min Volt / Cell 0	3.228 V Max Volt / Cell 0	3.216 V Min Volt / Cell 0	3.222 V Max Volt / Cell 0
353 Cycle Count		143 Cycle Count		0 Cycle Count		0 Cycle Count	

- **Min. Temp** – The cell number with the lowest temperature.
- **Max. Temp** – The cell number with the highest temperature.
- **Min. Volt** – The cell number with the lowest voltage.
- **Max. Volt** – The cell number with the highest voltage.
- **Cycle Count** – Number of times the battery has been fully charged and discharged.

2.8 INPUT & OUTPUT POWER


Located further down on the “Monitor” tab, the power curve for Input & Output Power per day can be found. The graph below displays the statistics for Solar PV, Battery, Grid, Consumption, SOC, and AC Coupling. These can also be selected individually to show input & output power.



- A. **Solar PV** – Displayed by a blue line.
- B. **Battery Discharged** – Displayed by a green line.
- C. **Grid** – Displayed by a red line.
- D. **Consumption** – Displayed by an orange line.
- E. **SOC** – Displayed by a purple line.
- F. **AC Couple** – Displayed by a dark blue line.

2.9 ENERGY OVERVIEW

At the bottom of the “Monitor” tab is the Energy Overview. This displays the Month, Year, and Total Solar Production, Battery, Export to Grid, Import to User, and Consumption.




- A. **Solar Production** – Displayed in light blue.
- B. **Battery Discharged** – Displayed in green.
- C. **Battery Charged** – Displayed in dark blue.
- D. **Export to Grid** – Displayed in red.
- E. **Import to User** – Displayed in brown and shows energy from the grid.
- F. **Consumption** – Displayed in orange and shows how much loads are consuming.
- G. **AC couple/Generator** – Displayed in blue.
- H. **Month** – Select to see energy statistics for each day.
- I. **Year** – Select to see energy statistics for each month.
- J. **Total** – Select to see energy statistics for each year.

3. DATA TAB

The “Data” tab displays detailed data, including technical details for PV, battery, grid, and loads, that are helpful for analysis, maintenance, and troubleshooting. The data tab is made up of five pages: Chart, Energy, Data History, Local Data, and Event History. For more details on each page, see the following tables.

3.1 CHART

Displays various parameters in chart format over a 24-hour period. There are separate charts for PV Side, Battery, AC Side, Backup Output, Gen Side, and Internal Sample.




The following table gives a brief description of the parameters found in the chart shown on the previous page:

Section	Name	Description
PV Side	Vpv	Voltage of solar input
	Ppv	Power of solar input
Battery	SOC(%)	Battery state of charge
	vBat(V)	Battery voltage
	Charge Power(W)	Total battery charging wattage
	Discharge Power(W)	Total battery discharging wattage
AC Side	Vacr(V)	Voltage of AC output
	Qac(Var)	Reactive power of AC output
	pToGrid(W)	Power being exported to the grid
	pFromGrid(W)	Power being utilized from the grid
	pACoupling(W)	Total power being utilized from AC coupled system
Backup Output	pLoad(W)	Power being utilized for the load
	V Backup Output r(V)	Load rated voltage
	F Backup Output(Hz)	Load frequency
	P Backup Output(W)	Load output power
Gen Side	S Backup Output(VA)	Load apparent power
	GenVolt(V)	Voltage of generator connected to inverter
	GenFreq(Hz)	Frequency of generator connected to inverter
Internal Sample 1	GenPower(W)	Amount of power being utilized from the generator
	vBus2(V)	2 nd sample from high voltage BUS
	Vbat_Inv(V)	Voltage sample from batteries after boost
	vBus1(V)	1 st sample from high voltage BUS
	vBusP(V)	Total high voltage sample

3.2 ENERGY

The “Energy” section displays how key energy parameters have varied over time by Month, Year, and Total.

- Selecting “Month” will show the energy statistics for each day of the month.
- Selecting “Year” will show energy for each month of the year.
- Selecting “Total” will show energy for each year.



Name	Description
E_pv_all(kWh)	Energy generated by entire PV array
E_pv1(kWh)	Energy generated by PV string 1
E_pv2(kWh)	Energy generated by PV string 2
E_inv(kWh)	Energy output via AC output
E_rec(kWh)	Energy of AC charge
E_charge(kWh)	Energy used for battery charge
E_discharge(kWh)	Energy output by battery discharging
E_backupPower(kWh)	Load energy output
EnergyToGrid(kWh)	Feed-in energy
EnergyFrom Grid(kWh)	Energy import from grid

3.3 DATA HISTORY

This page displays the measured technical values of PV, battery, load, and grid for users or their distributor's examination to promptly address any potential issues. Advanced technical knowledge is necessary to properly comprehend this table. End users are advised to concentrate solely on the "Monitor", "Chart", and "Energy" sections as these offer simple to comprehend performance data.



NOTE:

Data can be exported to an Excel file to be provided to the distributor for technical support. Distributors can then analyze the following factors to perform quick troubleshooting for their end users.

Serial number	Time	Status	Vpv1(V)	Vpv2(V)	Vpv3(V)	vBat(V)	SOC(%)	Ppv1(W)	Ppv2(W)	Ppv3(W)	pCharge(%)	pDisCharge	Vac(V)	Fac(Hz)	Pinv(r)	Prec(r)	PF(r)	Veps(r)	Vepss(V)	Vepst	
1	2024-04-12 12:17:51	0x8B	423.4	0	0.1	55.7	100%	42	0	0	38	0	0	25.6	0.1	0	0	[0]	242.3	0	0
2	2024-04-12 12:14:49	0xCO	427.1	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	241.6	0	0
3	2024-04-12 12:11:46	0xCO	425.8	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	241.4	0	0
4	2024-04-12 12:08:44	0x8B	425.8	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	242.3	0	0
5	2024-04-12 12:05:43	0x8B	425.9	0	0.1	55.7	100%	75	0	0	68	0	0	25.6	0.1	0	0	[0]	241.9	0	0
6	2024-04-12 12:02:42	0x8B	426.9	0	0.1	55.7	100%	13	0	0	12	0	0	25.6	0.1	0	0	[0]	241.6	0	0
7	2024-04-12 11:59:40	0x8B	428	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	241.4	0	0
8	2024-04-12 11:56:39	0xCO	428.8	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	242.3	0	0
9	2024-04-12 11:53:39	0xCO	427.7	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	241.6	0	0
10	2024-04-12 11:50:38	0x8B	429.3	0	0.1	55.7	100%	75	0	0	68	0	0	25.6	0.1	0	0	[0]	241.4	0	0
11	2024-04-12 11:47:36	0xCO	427.6	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	242.3	0	0
12	2024-04-12 11:44:32	0xCO	425	0	0.1	55.7	100%	0	0	0	0	0	0	25.6	0.1	0	0	[0]	241.6	0	0

Name	Description
PtoGrid/PtoUser	Checks if CT was connected correctly
Vpv/Ppv	Checks the MPPT
Vo/Po/So	Checks the load type and check if there is an overload when in load mode
Vb/SOC	Checks the current state of charge and if the battery is overcharged or overly discharged.
Vac/Fac	Evaluates Grid performance and to check if working voltage and frequency range is adjusted to comply with grid
E-xxday	Evaluates energy distribution
E-xxall	Checks if the system is working well under off grid mode

3.4 LOCAL DATA

The data captured during the offline periods is displayed in the "Local Data" section (loss of internet or Wi-Fi). The only distinction from "Data History" is that it is used for offline data recording. Local data is recorded while the system is offline for more than 20 minutes and is taken every 5 minutes. Data can be stored in the system for a maximum of 90 days.

Serial number	Time	Status	Vpv1(V)	Vpv2(V)	vBat(V)	SOC(%)	Ppv1(W)	Ppv2(W)	Ppv3(W)	pCharge(%)	pDisCharge	Vac(V)	Fac(Hz)	Pinv(W)	Prec(W)	PF	Veps(V)	Vepss(Hz)	Vepst(W)	Seps(VA)	pToGrid	pToUser	ePv1	ePv2	ePv3	ePo	eSo	eVb	eSOC	ePpv1	ePpv2	ePpv3	ePcharge	ePdischarge	eVac	eFac	ePinv	ePrec	ePF	eVeps	eVepss	eVepst	ePtoGrid	ePtoUser
---------------	------	--------	---------	---------	---------	--------	---------	---------	---------	------------	------------	--------	---------	---------	---------	----	---------	-----------	----------	----------	---------	---------	------	------	------	-----	-----	-----	------	-------	-------	-------	----------	-------------	------	------	-------	-------	-----	-------	--------	--------	----------	----------

3.5 EVENT HISTORY

The "Event History" page displays a timeline of Notice and Fault events. If there is not a record of a "historical event," the inverter is properly connected and working without any issues.

Station	Serial number	Event Type	Event	Start Time	Time Recovered
1		Notice	W016: No AC Connection	2024-04-12 09:21:36	
2		Notice	W026: Battery voltage low	2024-04-12 08:28:52	2024-04-12 09:21:36
3		Notice	W027: Battery open	2024-04-12 08:20:04	2024-04-12 09:21:36
4		Notice	W016: No AC Connection	2024-04-11 11:01:26	2024-04-12 08:26:52
5		Notice	W000: Communication failure with battery	2024-04-09 10:33:05	2024-04-09 12:49:40
6		Notice	W026: Battery voltage low	2024-04-09 09:58:07	2024-04-11 11:01:26
7		Notice	W027: Battery open	2024-04-09 09:22:58	2024-04-11 11:01:26

4. CONFIGURATION TAB

The "Configuration" tab is designated for users to manage their Stations, Dongles, Devices, and User information.

Station name	Country	Timezone	Daylight saving time	Create date	Action
1	United States of America	GMT -6	No	2023-09-15	Station Management
2	United States of America	GMT -6	No	2023-04-13	Station Management

4.1 STATIONS

The "Stations" page will show all stations linked to the account. Selecting a station name will display all inverters under that station or location.

Selecting the "Add Station" button creates another site if there is more than one station under the same account. This is useful for distributors who have multiple customers who would like assistance with monitoring/troubleshooting their inverters.

Station name	Country	Timezone	Daylight saving time	Create date	Action
1 (Station Name)	United States of America	GMT -5	Yes	2023-12-04	Station Management

4.2 DONGLES

Users can add a dongle Serial Number (SN) to the station if they have more than one inverter in the station. The inverter will be shown on the system once the dongle has been properly configured to communicate with the server and the inverter has been powered on.



IMPORTANT:

Before configuring the password for the Wi-Fi dongle, add the dongle to the monitor center.

Serial number	Dongle type	Station name	EndUser	Firmware	Create date	Connect Status	Last Update Time	Action
1	Wi-Fi		EndUser		2023-08-11	Lost	2024-01-18 13:05	Management
2					2023-09-22	Lost		Management
3	Wi-Fi				2023-08-02	Lost	2023-08-15 14:36	Management
4					2024-03-03	Lost		Management
5	Wi-Fi				2023-10-13	Connected	2024-03-07 14:26	Management

4.3 DEVICES

The “Devices” page displays any inverter tied to the user’s account, listed by serial number. Data can be exported to an Excel file for record keeping or to view specific inverter stats.

Serial number	Dongle	Station name	Device type	Battery type	Power Ra	Firmware	Status	Connect Status	BattParall	BattCapac	Export	Action
1		(Station Name)	6000XP	Lithium battery	6kW	cCaa-186168	PV&Battery Grid on	Connected	0	500	true	Management
2		(Station Name)	6000XP	Lithium battery	6kW	cCaa-186168	PV&Battery Grid on	Connected	5	500	true	Management

4.4 USERS

The “Users” page shows a full list of users, distributors and any other roles linked to the account. End users can modify passwords and edit personal information in the user page under the “User Management” drop down box. Distributors can add installer or end user accounts on this page.

Username	Nickname	Role	E-mail	Country	Timezone	Tel number	Address	Create date	Action
Docteam	enduser	EndUser		United States	GMT -6			2024-03-14	User Management

User Management

- Edit
- Modify password

Edit User

* Username: (User Name)

Nickname: Nickname

* E-mail: support@eg4electronics.com ✓

* Continent: North America

* Region: North America

* Country: United States of America

* Timezone: GMT -6

* Language: English

Tel number: Tel number

Address: Address

Update Back to user list

Modify Password

* Old Password: Old Password

* New Password: New Password

* Repeat password: Repeat password

Update Back to user list

5. OVERVIEW TAB

The “Overview” tab allows EG4® or its distributors to quickly monitor system-wide data for their end users, such as solar yields, battery discharging, and other factors.

5.1 STATION OVERVIEW

All the stations linked to the account can be found here. Selecting a station name will switch the main page to show the real time data.

Name	Status	SolarPower	ChargePower	DischargePower	Load	Solar Yield	BatteryDischarg	FeedEnergy	ConsumptionEn	Installer	EndUser
1	Offline	0 W	0 W	0 W	0 W	0 kWh	0 kWh	0 kWh	0 kWh		
2	Offline	0 W	0 W	0 W	0 W	0 kWh	0 kWh	0 kWh	0 kWh		
3	Offline	0 W	0 W	0 W	0 W	0 kWh	0 kWh	0 kWh	0 kWh		
4	Offline	0 W	0 W	0 W	0 W	0 kWh	0 kWh	0 kWh	0 kWh		

5.2 DEVICE OVERVIEW

All the inverters linked to the account can be found here. Selecting a serial number will switch the main page to show the real time data for that inverter.


Serial number	Status	Device type	SolarPower	ChargePower	DischargePow	Load	Solar Yield	BatteryDischa	FeedEnergy	Consumption	Station name	Parallel	Action
1	Offline	18KPV	0 W	0 W	0 W	0 W	0 kWh	3550.1 kWh	4330.2 kWh	0 kWh			
2	Offline	18KPV	0 W	0 W	0 W	0 W	0 kWh	64.9 kWh	16.9 kWh	39.8 kWh			
3	Offline	18KPV	0 W	0 W	0 W	0 W	273.1 kWh	5502.1 kWh	5191.1 kWh	79.1 kWh			
4	Notice	18KPV	13 W	12 W	0 W	0 W	36.7 kWh	30.1 kWh	1.9 kWh	244 kWh			
5	Normal	18KPV	0 W	0 W	11 kW	-221 W	36.6 kWh	17145.7 kWh	14848.1 kWh	0 kWh			
6	Offline	6000XP	0 W	0 W	0 W	0 W	0 kWh	35 kWh	0 kWh	12.2 kWh			
7	Offline	6000XP	0 W	0 W	0 W	0 W	387.1 kWh	651.8 kWh	0 kWh	156.2 kWh			
8	Offline	6000XP	0 W	0 W	0 W	0 W	0 kWh	13.2 kWh	0 kWh	0 kWh			
9	Normal	6000XP	5 kW	4 kW	0 W	0 W	181 kWh	144.4 kWh	0 kWh	20.4 kWh			

6. MAINTENANCE TAB

The “Maintenance” tab is used to remotely change settings on the inverter by selecting a station and then an inverter serial number. The Maintenance tab includes Remote Set, Weather Optimize, and Remote Update. See *image below*.

6.1 REMOTE SET

The “Remote Set” page is used to configure inverter settings. Select the station to begin configuring settings. Each sub-section is explained below.



Common Settings

▼
Common Setting

Time (?)

yyyy-MM-dd HH:mm:ss

Set

PV Input Mode (?)

<Empty>

Set

Start PV Volt(V)

[90, 500]

Set

Measurement (?)

<Empty>

▼

Battery Type (?)

<Empty>

▼

Lithium Brand (?)

<Empty>

▼

Set Model

Firmware version

LCD Version

- **Time:** Set the time/date of the inverter. The input format is 2019-02-14 14:44:00 (YYYY-MM-DD HH:MM:SS)
- **PV Input Mode:** The connection type of solar modules.
- **Start PV Volt (V):** Voltage at which the MPPT utilizes solar for loads/charging.
- **Measurement:** Choose the correct “Measurement” according to Meter Type or CT Sample Ratio according to the external measuring device that is installed. The default measurement is 1000/1. The measurement can be adjusted if there is a meter connected to the inverter.
- **Battery Type:** Choose the “Battery Type” and then select Lithium Brand (for closed-loop communications), or battery capacity for lead-acid/lithium batteries with no communications.
Note: after setting the battery type, all other settings will reset to default.
- **Lead-acid Capacity:** Set the total capacity when using lead-acid batteries.
- **Lithium Brand:** Choose the brand of lithium battery being used.
- **Firmware version:** Shows the current firmware version being used.
- **LCD Version:** Shows the current LCD version being used.



NOTE:

When the “Model” settings need to be changed, users need to set inverter to “Standby” in the Application Settings menu first, then select “Set Model” to change the model.

Application Settings

The screenshot displays the 'Application Setting' interface with the following controls:

- No Batteries** (Enable/Disable)
- Power Backup** (Enable/Disable)
- Grid Sell Back** (Enable/Disable)
- Fast Zero Export** (Enable/Disable)
- PV Arc** (Enable/Disable)
- Grid Loss Warning Clear** (Enable/Disable)
- Normal / Standby** (Normal/Standby)
- Micro-Grid** (Enable/Disable)
- System Charge SOC Limit(%)** (Input: [10, 101] Set)
- Seamless EPS switching** (Enable/Disable)
- Grid Sell Back Power(kW)** (Input: [0, 25.5] Set)
- Off-Grid Mode** (Enable/Disable)
- PV Arc Fault Clear** (Clear)
- RSD** (Enable/Disable)
- Restart Inverter** (Restart)
- Max. AC Input Power(kW)** (Input: [0, 6553.5] Set)
- System Charge Volt Limit(V)** (Input: [40, 59.5] Set)

Parallel System

- Set System Type** (Dropdown: <Empty> Set)
- Share Battery** (Enable/Disable)
- Set Composed Phase** (Dropdowns: <Empty> <Empty> Set)
- Parallel Setting Data Sync** (Enable/Disable)

- **No Batteries:** Allows access to off-grid mode when only solar input is available without battery storage.
- **Power Backup:** If “Power Backup” function is Enabled, the LOAD terminal will maintain output when AC is interrupted. “Power Backup” can be set via the web or “Off-Grid Output” by LCD. (When enabling this mode, the inverter’s output will be uninterrupted.)
- **Seamless EPS Switching:** When power is interrupted, the inverter will seamlessly switch to EPS mode unless there is a grid voltage fluctuation issue; in which case, we suggest setting to “Disable” to avoid misjudgment.
- **Grid Sell Back:** In some cases, the customer cannot feed energy into grid. If the customer does not want to feed energy to the grid, the “Grid Sell Back” function can be disabled.
- **Grid Sell Back Power(kW):** If “Grid Sell Back” function is enabled, the power limitation feed can be adjusted.
- **Fast Zero Export:** Normally, the inverter will adjust output power every 5 seconds to avoid export. If “Fast Zero Export” is enabled, the inverter will adjust output power accordingly.
- **Off-Grid Mode:** Enable for nominal Off-Grid operations while utilizing AC input as a backup power source, allowing for absolute zero export.
- **PV Arc:** The inverter will detect when there is an arc fault on the PV inputs in order to protect itself from potential damage.
- **PV Arc Fault Clear:** Clear the records of PV arc fault.
- **Grid Loss Warning Clear:** Enable for an absolute Off-Grid system. The “No AC Connection” and “AC V /F out of range” warning will not occur when enabled.
- **RSD:** The rapid shut-down detection of the PV inputs.
- **Normal/Standby:** “Standby” is used to set the system into standby mode, stopping feed in, charge and discharge. “Normal” is used to set the whole system to auto run status.
- **Restart Inverter:** Restarts the inverter.
- **Micro-Grid:** Should be set only when the generator is connected to the Inverter’s Grid terminal. With this option enabled, the inverter will use AC power to charge the battery and will not export any power through the Grid terminal if AC power is present at the inverter’s Grid terminal.
- **Max. AC Input Power(kW):** The inverter can adjust the charge power based on the detected inverter’s load consumption and “Max. AC Input Power(kW)” limitation.
- **System Charge SOC Limit(%):** The limit to which the battery can be charged measured by SOC%. Once set, the battery SOC will not exceed the set value.

- **System Charge Volt Limit(V):** The limit to which the battery can be charged measured by voltage. Once set, the battery voltage will not exceed the set value.

Parallel System

Set System Type (?) <Empty> Set Share Battery (?) Enable Disable

Set Composed Phase (?) <Empty> <Empty> Set Parallel Setting Data Sync (?) Enable Disable

- **Set System Type:** EG4® inverters support paralleling of multiple inverters. In this scenario, one of the inverters must be set to Master and the others set to Slave. If all inverters are installed as single-phase, be sure to set one of the inverters to “1 Phase Master.” If a three-phase system is needed, set one of the inverters to “3 Phase Master.” All inverters are set to Slaves by default. Upon purchase/receipt of the inverters, one will need to be set to Master before paralleling multiple inverters.
- **Share Battery:** For paralleled systems: if all inverters connect to same battery bank, “Share Battery” must be enabled. The Master inverter will broadcast the battery information to all other inverters.
- **Set Composed Phase:** When using ≥ 3 inverters to compose a three-phase system, the AC terminals of the inverter must be connected to a three-phase grid. If the system is connected to the grid, the inverter will detect the phase it connects to automatically, record it and output the phase as it detected. If the user setting is different from the phase the inverter detected, it will output the phase detected. The output phase record will be cleared if the customer clears it. If the system is not connected to the grid, the inverter will use the user output phase setting to compose the three-phase output. If the customer sets the wrong phase (i.e., 2 U phase and no W phase) the system will report error.
- **Parallel Setting Data Sync:** Syncs master inverter settings to those of the slave inverter(s).

Grid Connect Settings

Grid Connect Setting

Grid Frequency(Hz) (?) <Empty> Set Grid Type (?) <Empty> Set

- **Grid Frequency:** If the “Grid Frequency” is nominal at 50Hz, then the inverter’s frequency will be adjusted to 50Hz automatically. If there is no grid power and it is read as 50Hz, but the devices are 60Hz, then it can be set to 60Hz manually. This is based on the rated frequency of the local grid regulation and devices.



WARNING:

Settings should be adjusted while the device is on Standby. Ensure this setting is correctly configured before powering on the system. Using the wrong power frequency can lead to home appliance damage.

- **Grid Type:** Select the correct “Grid type” to function, such as split phase: 240/120 or 208/120V.

Charge Settings

The screenshot displays the 'Charge Setting' interface with the following sections and controls:

- Batt Charge Control (7):** Selectable between 'Volt' and 'SOC'.
- Charge Current Limit(Adc) (7):** Input field set to 0.500 with a 'Set' button.
- Charge Last (7):** Toggle between 'Enable' and 'Disable'.
- Battery Backup Mode:** Toggle between 'Enable' and 'Disable'.
- AC Charge Section:**
 - AC Charge Enable (7):** Toggle between 'Enable' and 'Disable'.
 - AC Charge Based On (7):** Dropdown menu set to '<Empty>' with a 'Set' button.
 - AC Charge Power(kW) (7):** Input field set to 0.25.0 with a 'Set' button.
 - Start AC Charge SOC(%)** and **Stop AC Charge SOC(%)**: Input fields set to 0.90 and 0.100 respectively, each with a 'Set' button.
 - Start AC Charge Volt(V)** and **Stop AC Charge Volt(V)**: Input fields set to 140.57 and 142.98 respectively, each with a 'Set' button.
 - AC Charge Start Time 1-3** and **AC Charge End Time 1-3**: Time range inputs (HH:MM) with 'Set' buttons.
- Battery Backup Mode Section:**
 - PV Charge Priority (7):** Toggle between 'Enable' and 'Disable'.
 - PV Charge Power(kW)** and **PV Charge Priority Stop SOC(%) (7)**: Input fields set to 0.25.0 and 0.100 respectively, each with a 'Set' button.
 - PV Charge Priority Stop Volt(V)**: Input field set to 142.98 with a 'Set' button.
 - Battery Priority Start Time 1-3** and **Battery Priority End Time 1-3**: Time range inputs (HH:MM) with 'Set' buttons.

- **Battery Charge Control:** If the inverter communicates with the lithium battery and is capable of closed-loop communication, then select “Batt. Charge Control” according to “SOC.” If communication is not available, users can select “Batt. Charge Control” according to “VOLT.”
- **Charge Current Limit (Adc):** The maximum charge current limitation of the entire system.
- **Charge Last:** Charges battery last.
- **AC Charge Enable:** If using AC (i.e., the Grid) to charge the battery, the customer must (1) “Enable” AC Charge Enable, (2) set the max power to charge the battery from AC; “AC Charge Power (kW)”, (3) set the SOC and Voltage Limits; “Start AC Charge SOC(%) / Volt(V)” and “Stop AC Charge SOC (%) / Volt(V)” and (4) set the time period to use the AC to charge the battery. There are 3 time periods that can be set. If the battery SOC and Voltage is within the limits, the system will use AC from the Grid to charge the battery during the time that is set.
- **AC Charge Based On:** According to time: Set a preferred time period to charge the battery range: 00:00 – 23:59. According to voltage: Set AC to charge the battery when it drops to a pre-set voltage. Range: 50-59V.
- **AC Charge Power (kW):** The max charging power from grid.
- **AC Charge:** Set AC charging according to Time or Volt(V)/SOC (%).
- **Start AC Charge SOC(%) / Volt(V):** Limit of SOC and Voltage at which system will start charging batteries from AC.
- **Stop AC Charge SOC(%) / Volt(V):** Limit of SOC and Voltage at which system will stop charging batteries from Grid.
- **AC Charge Start Time 1-3:** Start AC Charging according to these time settings.
- **AC Charge End Time 1-3:** Stop AC Charging according to these time settings.
- **PV Charge Priority:** In this mode, solar will charge battery first. After charging batteries, solar will supply any loads. Lastly, it will feed into the grid if surplus power is generated.
- **PV Charge Power(kW):** The max charging power from solar.
- **PV Charge Priority Stop SOC (%):** When SOC reaches this limit, charge first mode will end.
- **PV Charge Priority Stop Volt (V):** When voltage reaches this limit, charge first mode will end.
- **Battery Priority Start Time 1-3:** Start time for charge first setting.
- **Battery Priority End Time 1-3:** End time for charge first setting.

Generator Charge Settings

Generator Charge

Generator

Generator Boost: Enable Disable

Generator Cool-Down Time(Min): Set

Batt Charge Current Limit(Adc) (?): Set

Gen Rated Power(kW) (?): Set

Charge Start Volt(V) (?): Set

Charge Start SOC(%): Set

Charge End Volt(V): Set

Charge End SOC(%): Set

- **Generator Boost Enable/Disable:** Enable or disable the generator boost feature. Enable to allow the inverter to pull supplemental power from both PV and battery whenever the generator power is not sufficient to handle all loads.
- **Generator Cool-Down Time(Min):** Set the cool-down time period for the generator before re-engaging the generator’s output to the inverter.
- **Batt Charge Current Limitation(Adc):** Battery charge current limitation from Generator.
- **Gen Rated Power(kW):** The battery charge power can be limited based on the detected inverter’s load consumption and Generator input power limitations.
- **Charge Starts Volt(V)/SOC(%):** While using auto-start function of the generator, the “Charge Start Voltage / SOC (%)” can be limited to start up the generator automatically.
- **Charge End Volt(V)/SOC(%):** While using auto-start function of the generator, the “Charge End Voltage / SOC (%)” can be limited to turn off the generator automatically.

Discharge Settings

Discharge Setting

Batt Discharge Control (?): VOLT SOC

Discharge Current Limit(Adc) (?): Set

Start Discharge P_import(W) (?): Set

On-Grid Cut-Off SOC(%) (?): Set

Off-Grid Cut-Off SOC(%) (?): Set

On-Grid Cut-Off Volt(V) (?): Set

Off-Grid Cut-Off Volt(V) (?): Set

Forced Discharge

Forced Discharge Enable (?): Enable Disable

Forced Discharge Power(kW) (?): Set

Stop Discharge SOC(%) (?): Set

Stop Discharge Volt(V): Set

PV5allToGrid(Comp. w/ REM3.0) (?): Enable Disable

Forced Discharge Start Time 1: Set

Forced Discharge Start Time 2: Set

Forced Discharge Start Time 3: Set

Forced Discharge End Time 1: Set

Forced Discharge End Time 2: Set

Forced Discharge End Time 3: Set

Peak Shaving

Grid Peak-Shaving (?): Enable Disable

Grid Peak-Shaving Power 1(kW) (?): Set

Grid Peak-Shaving Power 2(kW) (?): Set

Start Peak-Shaving Volt 1(V): Set

Start Peak-Shaving Volt 2(V): Set

Start Peak-Shaving SOC 1(%): Set

Start Peak-Shaving SOC 2(%): Set

Peak Shaving Start Time 1: Set

Peak Shaving Start Time 2: Set

Peak Shaving End Time 1: Set

Peak Shaving End Time 2: Set

AC Couple

AC Couple (?): Enable Disable

AC Couple Start Volt(V): Set

AC Couple Start SOC(%) : Set

AC Couple End Volt(V): Set

AC Couple End SOC(%) : Set

Smart Load

Smart Load (?): Enable Disable

Smart PV Power(kW) (?): Set

Grid Always On (?): Enable Disable

Smart Load Start Volt(V): Set

Smart Load Start SOC(%) : Set

Smart Load End Volt(V): Set

Smart Load End SOC(%) : Set

- **Batt Discharge Control:** If the inverter communicates with the lithium battery and is capable of closed-loop communication, users should select “Batt. Discharge Control” according to “SOC.” When using lead-acid batteries or lithium batteries without communication, users should select discharge control according to “VOLT.”
- **Discharge Current Limit (Adc):** The Max. discharge current limit when grid power is on.
- **Start Discharge P_Import(W):** Default value is 100 which means the battery will begin to discharge power to take the load when the import power from grid is higher than 100W. (Adjust range [50-100]).

- **On-Grid Cut-Off SOC(%)/Volt(V):** When the inverter connects to the grid and if the battery is discharging to take the load, it will stop discharge when the SOC/Voltage is lower than this limit.
- **Off-Grid Cut-Off SOC(%)/Volt(V):** When the inverter is not connected to the grid and the battery is discharging to take the load, the battery will stop discharging when the SOC/Voltage is lower than this limit.
- **Forced Discharge Enable/Disable:** If the customer wants to simply discharge the battery, they can enable forced discharge function and set both the discharge power and time period.
- **Forced Discharge Power(kW):** Forced discharge power limit.
- **Stop Discharge SOC(%)/Volt(V):** If Battery SOC is lower than this limit, the inverter will stop forced discharging function.
- **PV Sell To Grid(Comp. w/ NEM3.0):** Enable or disable PV sell back to grid feature.
- **Forced Discharge Start Time 1-3:** Start time for Forced Discharge.
- **Forced Discharge End Time 1-3:** End time for Forced Discharge.
- **Grid Peak-Shaving:** Peak-Shaving is used to avoid peak demand charges from the grid. Peak shaving can be accomplished by halting Grid Charging at specific times. For example, during periods of peak demand (i.e., high grid rates), or when the batteries are near fully charged based on SOC and Voltage.
- **Grid Peak-Shaving Power 1-2(kW):** Used to set the maximum power that the inverter can draw from the grid.
- **Start Peak-Shaving Volt(V)/SOC(%) 1-2:** The point at which Peak-Shaving starts.
- **Peak-Shaving Start Time 1-2:** The time of day at which charging by the grid will be halted.
- **Peak-Shaving End Time 1-2:** The time of day at which charging by the grid will resume.
- **AC Couple Enable/Disable:** When connecting an existing on-grid system to the GEN terminal, AC Couple must be set to enable.
- **AC Couple Start Volt(V)/SOC (%):** AC Coupling will start at this set Voltage/SOC.
- **AC Couple Stop Volt(V)/SOC (%):** AC Coupling will stop at this set Voltage/SOC.
- **Smart Load Enable/Disable:** When Smart load function is enabled, the GEN terminal will be reused to Smart Load, and the inverter will offer power to this load based on the setup values.
- **Start PV Power (kW):** This is the minimum PV power limit to function with smart load output.
- **On Grid Always On:** Once this function is enabled, smart load will always function when grid power is on.
- **Smart Load Start SOC (%) / Volt (V):** The high limit for battery to turn on smart load.
- **Smart Load Stop SOC (%) / Volt (V):** The low limit for battery to turn off smart load.

Battery

▼ Battery Read

Restart Battery Module 0

Restart Battery Module

- **Restart battery module**

Reset

▼ Reset


All to Default Reset

- **Reset:** Reset all settings to default.


Working Mode

The “Working Mode” feature has several different preset working modes that allow the user to configure the system to meet their needs through customizing settings. Working modes include Backup Mode, Peak Shaving, AC Charge Mode, PV Charge Priority, Forced Discharge/Export PV Only, and Self Consumption. The steps to access the working modes and a brief description of the modes are outlined below.

1. In the “Maintenance” tab on the Remote Set page, ensure that the correct station is selected. Select “Read” (*shown below*) for the Monitor Center to fetch the default or pre-configured settings for the station. Located to the top right of the page, select “Working Mode”.



2. After “Working Mode” is selected, navigate below Application Settings for the “Working Mode Setting” section (*shown below*). This section gives users access to configure the system to their own needs by utilizing both settings and time of use periods.



- **Backup Mode:** The system prioritizes battery backup/storage by ensuring the battery is only utilized when PV and Grid power is not sufficient for powering loads.
- **Peak Shaving:** The user can define a time-frame of when the system will compensate the power pulled from the grid for loads during peak demand times to avoid higher electricity rates.
- **AC Charge Mode:** Allows the grid to both charge batteries and power loads.
- **PV Charge Priority:** Prioritizes PV power to charge batteries first.
- **Forced Discharge/Export PV Only:** Forced discharge prioritizes battery power for powering loads and grid sell back. Export PV Only prioritizes PV power to export to the power grid.
- **Self Consumption:** Prioritizes the energy stored/generated from the system to power loads.

Upon selecting a “Working Mode”, the system must be configured using specific settings for each mode. For required information concerning the settings of each Working Mode, scan the QR codes.

6000XP Monitor System Working Modes




18kPV Monitor System Working Modes



Export Pdf

The “Export PDF” feature creates a PDF document with the system’s selected settings and values for ease of troubleshooting. To use the Export PDF function, ensure the correct station is selected. Select “Read” for the Monitor Center to fetch the default or pre-configured settings for the station. If “Read” is not selected before trying to Export PDF, the PDF will be missing the specified settings and values. Next, select “Export PDF” (*shown below*) to create a document showing the system settings.



6.2 WEATHER OPTIMIZE

The “Weather Optimize” feature uses real-time weather information to adjust charging strategies based on tomorrow’s local weather conditions, ensuring the battery bank remains adequately charged. Weather Optimize reviews the weather one day at a time starting at 5pm the day before. All weather data is based on the forecast from openweathermap.org. For example, if heavy rain is predicted in the next day’s forecast the battery bank will be charged to the heavy rain SOC value as configured in charge percent (%) by weather area. The configuration steps are outlined below:

1. To enable Weather Optimize, the device will need to be added. To add the device, select “Add Device” (*shown below*). The Charge Start Time, Charge End Time and SOC values are populated with default values. All the values can be changed to the preferred time and percentages. Once the desired settings are adjusted, select “Add” to save the changes.

The screenshot displays the EG4 Electronics web interface. At the top, there is a navigation bar with icons for Monitor, Data, Configuration, Overview, and Maintenance. Below this, a sidebar on the left contains 'Remote Set' and 'Remote Update' sections, with 'Weather Optimize' highlighted in yellow. The main content area shows a table with two rows of device information. A blue box highlights the 'Add device' button in the top right of the table area. Another blue box highlights a pin icon in the 'Location' column of the second row. Below the table, two pop-up windows are shown. The first is the 'Add device' form, which includes fields for Serial number, Charge Start Time (00:30), Charge End Time (04:00), and a section for 'Charge percent(%) by weather' with input fields for Clear sky (30), Few(11%-25%) clouds (65), Scattered(25%-50%) clouds (75), Broken(51%-84%) clouds (85), Overcast(85%-100%) clouds (95), Light rain (80), Moderate rain (90), Heavy rain (100), and Other (90). The 'Add' button is highlighted in blue. The second pop-up window is for location selection, showing a map of the area around Commerce, VA, with coordinates 33.12560950064763, -95.58642794451929. It also includes fields for Create time (2024-04-16), Continent (North America), Region (North America), Country (United States of America), Timezone (GMT -6), and Daylight saving time (No). The 'Update' button is highlighted in blue.

2. After the device is added, the location for the device needs to be set. Select the pin icon (*shown above*) and use the map, latitude and longitude coordinates, or the search option to select a location. Without a set location, there will be a red X next to the pin icon and Weather Optimize will not function. Once all location settings have been verified as correct, select the “Update” button to save the location. The red X should be changed to a green check.

- Users can edit the Charge Start Time, Charge End Time and SOC percentages, by selecting the “Management” drop down menu and selecting “Edit” (*shown below*). Once settings are changed to the preferred values, select the yellow “Edit” button to save the changes.

The screenshot displays the EG4 Electronics web interface. The top navigation bar includes 'Monitor', 'Data', 'Configuration', 'Overview', and 'Maintenance'. The 'Configuration' page shows a table of devices with columns for 'Serial number', 'Station name', 'Charge Time Range', 'Location', and 'Action'. The 'Action' column for the selected device shows a 'Management' dropdown menu with 'Edit' and 'Disable' options. An 'Edit' dialog box is open, showing fields for 'Serial number', 'Charge Start Time', 'Charge End Time', and 'Charge percent(%) by weather' for various weather conditions.

Serial number	Station name	Charge Time Range	Location	Action
1		00:30 - 04:00	✓	Management
2		00:30 - 04:00	✓	Management

Edit dialog box fields:

- * Serial number
- * Charge Start Time: 00:30
- * Charge End Time: 04:00
- Charge percent(%) by weather:
 - * Clear sky: 30
 - * Few(11%-25%) clouds: 65
 - * Scattered(25%-50%) clouds: 75
 - * Broken(51%-84%) clouds: 85
 - * Overcast(85%-100%) clouds: 95
 - * Light rain: 80
 - * Moderate rain: 90
 - * Heavy rain: 100
 - * Other: 90



NOTE:

At this time, the 6000XP does not support the Weather Optimization feature.

6.3 REMOTE UPDATE

The “Remote Update” page allows users to check and upgrade firmware on the inverters connected to the account. To check for available updates, select the blue question mark (shown below). If there is a suggested update the firmware version will be displayed. From the Check Updates window, selecting “Check more” will redirect to the Firmware Change log.

The screenshot displays the EG4 Electronics web interface. At the top, there is a navigation bar with icons for Monitor, Data, Configuration, Overview, and Maintenance. Below this, the 'Remote Set' section includes a search bar and filters for 'Station', 'Online Device', and 'Auto Reload'. A table lists inverters with columns for 'Serial number', 'Dongle', 'Firmware version', 'Connect Status', and 'Action'. A blue question mark icon in the 'Firmware version' column is highlighted with a blue box and an arrow pointing to a 'Check Updates' modal window.

The 'Check Updates' modal window shows fields for 'Serial number', 'Firmware version', and 'Suggestion' (No updates). A 'Check more ->' button is highlighted with a blue box and an arrow pointing to the 'Firmware Change log' page.

The 'Firmware Change log' page features a dropdown menu for '18KPV-12LV' and an 'export PDF' button. It lists firmware versions under 'Log and version updates':

- FAAB-1B1B** (2024-06-19): Same as FAAB-1B1B, changes based on the FAAB-1A1A. 1. Fixed an issue when inverter in off-grid mode, inverter can't use generator to take load and charge battery. 2. Optimized the logic of on-grid load taking.
- FAAB-1A1A** (2024-04-22): Same as FAAB-1A1A, changes based on the FAAB-1919.

At the bottom, there is a pagination bar showing 'Page 1 of 1' and 'Displaying 1 to 1 of 1 items'.



CONTACT US

support@eg4electronics.com

(903) 609-1988

www.eg4electronics.com